1121 Washington St. Newton, MA 02465 V/TTY 617.641.2802 FAX 617.641.2812 www.kmaccess.com info@kmaccess.com

# FHA: Examples of Adaptable Elements for Multi-Family Housing

# **Examples of Adaptable Elements Specifically Permitted**

### Changes In Level At Exterior Balconies And Patios.

Where exterior deck, patio or balcony surface materials are impervious, the finished exterior impervious surface may be 4 inches maximum below the floor level of the adjacent interior spaces of the unit.

### **Bathroom Lavatory and Kitchen Sink**

If a front approach is planned, cabinetry is permitted under the lavatory/sink provided:

- 1. Required knee space must be provided at the time of initial construction;
- 2. The cabinetry can be removed without removing or replacing the lavatory/countertop, and
- 3. The wall and floor finishes extend under the cabinetry.

### Examples of elements required to be accessible at the time of first occupancy.

# Doors within dwelling units intended for user passage (e.g. bathrooms, bedrooms & walk-in closets)

Provide a minimum 31 5/8" clear width.

#### **Bathroom Clear Floor Space**

A 30" x 48" clear floor space out of the swing of the door.

### Clear floor space at ranges, cooktops and sinks

"Unless knee space is provided, space to execute a parallel approach must be provided at ranges, cooktops, and sinks." The clear floor space for a parallel approach must be centered on the range, cooktop or sink.

Clear Floor Space at Ovens, Dishwashers, Refrigerators, Freezers, and Trash Compactors A clear 30" x 48" space for either a front or parallel and centered approach must be provided.

<sup>&</sup>lt;sup>1</sup> FHA Design Manual pg 7.4

# Clearance between kitchen counters and all opposing elements

A minimum 40" clearance must be provided between counters and all opposing elements.

In U shaped kitchens, a 60" turning diameter must be provided (or a cooktop or sink with knee space for a forward approach is provided at the base of the U)

Wall Reinforcement for the future installation of grab bars.

## Height of receptacles and thermostats

Receptacles not over counters must be a minimum 15" AFF to the CL of the lowest receptacles. The highest operable part of thermostats should be 48" AFF maximum.

